

Town of Wawarsing Swimming Pool Permit Application

Town of Wawarsing, Building Department, 108 Canal Street, PO Box 671, Ellenville, NY 12428
Office: (845)647-7800 ext. 5, Fax: (845)647-1824, wawbuilding@gmail.com

Section, _____ Block, _____ Lot, _____ Permit #, _____

Address for proposed location of pool: _____

Definition of Swimming Pool under the Uniform Building Code: Any structure, basin, chamber or tank which is intended for swimming, diving, recreational bathing or wading and which contains, is designed to contain, or is capable of containing water more than 24 inches (610mm) deep at any point. This includes in-ground, above-ground, and on-ground pools; indoor pools; hot tubs; spas; and fixed-in-place wading pools.

Primary use of property: _____ Estimated Cost of Construction: \$ _____

Max. Depth of Pool: _____ inches. Aprx. Water Capacity: _____ gal. Permit Fee: \$ _____

Distance to property lines: Nearest front lot line: _____ ft. Nearest rear lot line: _____ ft. Nearest side lot line: _____ ft.

Yes or No: Spa or Hot-tub? _____ Installed on a deck? _____ Above-ground pool? _____ Heated? _____ Indoor? _____ New deck? _____

Information About Owner of Premises: Name: _____

Mailing Address: _____

E-Mail Address: _____ Phone Number: _____

Information About Applicant: Name: _____

Relationship to Owner of Premises: _____

Mailing Address: _____

E-Mail Address: _____ Phone Number: _____

General Contractor's Information: Name: _____

Mailing Address: _____

E-Mail Address: _____ Phone Number: _____

Electrician's Information: Name: _____

Mailing Address: _____

E-Mail Address: _____ Phone Number: _____

Professional Designer's Information: Name: _____

Mailing Address: _____

E-Mail Address: _____ Phone Number: _____

By signing below I, the applicant, consent to permit access without notice to the work area by code enforcement officials during both regular business hours and at any time while construction or installation activity occurs. I understand that all work must be completed according to law despite any approvals that may be granted in error.

Signature of Applicant: _____ Date: _____

****Draw a sketch plan of the site with construction details on the back of this application.****

****Attach manufacturer's details, proof of WC&DB insurance, and other details as needed.****

Appendix G - Swimming Pools, Spas and Hot Tubs

SECTION G101 GENERAL

G101.1 General. The provisions of this appendix shall control the design and construction of swimming pools, spas and hot tubs installed in or on the lot of a one- or two-family dwelling.

SECTION G102 DEFINITIONS

G102.1 General. For the purposes of these requirements, the terms used shall be defined as follows and as set forth in Chapter 2.

BARRIER PERMANENT. A fence, wall, building wall or combination thereof which completely surrounds the swimming pool and obstructs access to the swimming pool.

BARRIER TEMPORARY. An approved temporary fence, permanent fence, the wall of a permanent structure, any other structure, or any combination thereof that prevents access to the swimming pool by any person not engaged in the installation or construction of the swimming pool during its installation or construction.

HOT TUB. See "Swimming pool."

IN-GROUND POOL. See "Swimming pool."

RESIDENTIAL. That which is situated on the premises of a detached one- or two-family dwelling or a one-family townhouse not more than three stories in height.

SPA, NONPORTABLE. See "Swimming pool."

SPA, PORTABLE. A nonpermanent structure intended for recreational bathing, in which all controls, water-heating and water-circulating equipment are an integral part of the product.

SUBSTANTIAL DAMAGE. For the purpose of determining compliance with the pool alarm provisions of this appendix, damage of any origin sustained by a swimming pool whereby the cost of restoring the swimming pool to its before-damaged condition would equal or exceed 50 percent of the market value of the swimming pool before the damage occurred.

SUBSTANTIAL MODIFICATION. For the purpose of determining compliance with the pool alarm provisions of this appendix, any repair, alteration, addition or improvement of a swimming pool, the cost of which equals or exceeds 50 percent of the market value of the swimming pool before the improvement or repair is started. If a swimming pool has sustained substantial damage, any repairs are considered substantial modification regardless of the actual repair work performed.

SWIMMING POOL. Any structure, basin, chamber or tank which is intended for swimming, diving, recreational bathing or wading and which contains, is designed to contain, or is capable of containing water more than 24 inches (610 mm) deep at any point. This includes in-ground, above-ground and on-ground pools; indoor pools; hot tubs; spas; and fixed-in-place wading pools.

SWIMMING POOL, INDOOR. A swimming pool which is totally contained within a structure and surrounded on all four sides by the walls of the enclosing structure.

SWIMMING POOL, OUTDOOR. Any swimming pool which is not an indoor pool.

Building Department

TOWN OF WAWARSING
108 Canal Street, P.O. Box 671
Ellenville, New York 12428
Phone: 845-647-7800
Fax: 845-647-1824

*****Insurance Requirements*****

New York State requires proof of Workers Comp and Disability Insurance or proof of legal exemption from them. Please use the guidelines below to determine which forms need to be provided. The BP-1 form is available on our website and the CE-200 form is generated from the NYS Workers Comp website. The remaining forms must be obtained from your insurance broker.

- 1) If applicant is **Owner** of 1,2,3,or 4 Family **Owner-Occupied Residence** AND owner is performing all the work, **OR** owner is not compensating the individual performing the work **OR** owner is paying individuals a total of less than 40 hours a week:

Owner Occupied Exemption Form BP-1 (9-07) _____

- 2) If applicant is **Business** or **General Contractor**, or **Owner** who does not qualify for above exemption, we require one of the following proofs of workers' compensation and disability insurance (either A, B or C):

- A) Affidavit of Exemption from Workers Comp and Disability: Form CE-200 (12/08) _____ Print from the NYS Workers Comp website and submit

to our office: <http://www.web.state.ny.us> then click on WC/DB Exemptions Form CE-200

- B) Certificates of Workers' Compensation Insurance and Disability Benefits Insurance:
(Workers Comp) Form C-105.2 _____ or State Insurance Fund Form U-26.3 _____

AND

(Disability) Form DB-120.1 _____

- C) Self-insured or participating in authorized self-insurance plan:
Form SI-12 _____ or Form GSI -105.2 _____

AND

Form DB-155 _____

ACORD forms are NOT acceptable proof of NY State Workers' Compensation or Disability Insurance coverage!

SECTION G103 SWIMMING POOLS

G103.1 In-ground pools. In-ground pools shall be designed and constructed in conformance with ANSI/NSPI-5 as listed in Section AG108.

G103.2 Above-ground and on-ground pools. Above-ground and on-ground pools shall be designed and constructed in conformance with ANSI/NSPI-4 as listed in Section AG108.

SECTION G104 SPAS AND HOT TUBS

G104.1 Permanently installed spas and hot tubs. Permanently installed spas and hot tubs shall be designed and constructed in conformance with ANSI/NSPI-3 as listed in Section AG108.

G104.2 Portable spas and hot tubs. Portable spas and hot tubs shall be designed and constructed in conformance with ANSI/NSPI-6 as listed in Section AG108.

SECTION G105 BARRIER REQUIREMENTS

G105.1 Application. The provisions of this chapter shall control the design of barriers for residential swimming pools, spas and hot tubs. These design controls are intended to provide protection against potential drownings and near-drownings by restricting access to swimming pools, spas and hot tubs.

G105.2 Temporary barriers. An outdoor swimming pool, including an in-ground, above-ground or on-ground pool, hot tub or spa shall be surrounded by a temporary barrier during installation or construction and shall remain in place until a permanent barrier in compliance with Section AG105.3 is provided.

Exceptions:

1. Above-ground or on-ground pools where the pool structure is the barrier in compliance with Section AG105.3.
2. Spas or hot tubs with a safety cover which complies with ASTM F 1346, as listed in Section AG107, provided that such safety cover is in place during the period of installation or construction of such hot tub or spa. The temporary removal of a safety cover as required to facilitate the installation or construction of a hot tub or spa during periods when at least one person engaged in the installation or construction is present is permitted.

G105.2.1 Height. The top of the temporary barrier shall be at least 48 inches (1219 mm) above grade measured on the side of the barrier which faces away from the swimming pool.

G105.2.2 Replacement by a permanent barrier. A temporary barrier shall be replaced by a complying permanent barrier within either of the following periods:

1. 90 days of the date of issuance of the building permit for the installation or construction of the swimming pool; or
2. 90 days of the date of commencement of the installation or construction of the swimming pool.

G105.2.2.1 Replacement extension. Subject to the approval of the code enforcement official, the time period for completion of the permanent barrier may be extended for good cause, including, but not limited to, adverse weather conditions delaying construction.

G105.3 Outdoor swimming pool. An outdoor swimming pool, including an in-ground, above-ground or on-ground pool, hot tub or spa shall be surrounded by a barrier which shall comply with the following:

1. The top of the barrier shall be at least 48 inches (1219 mm) above grade measured on the side of the barrier which faces away from the swimming pool. The maximum vertical clearance between grade and the bottom of the barrier shall be 2 inches (51 mm) measured on the side of the barrier which faces away from the swimming pool. Where the top of the pool structure is above grade, such as an above-ground pool, the barrier may be at ground level, such as the pool structure, or

mounted on top of the pool structure. Where the barrier is mounted on top of the pool structure, the maximum vertical clearance between the top of the pool structure and the bottom of the barrier shall be 4 inches (102 mm).

2. Openings in the barrier shall not allow passage of a 4-inch-diameter (102 mm) sphere.

3. Solid barriers which do not have openings, such as a masonry or stone wall, shall not contain indentations or protrusions except for normal construction tolerances and tooled masonry joints.

4. Where the barrier is composed of horizontal and vertical members and the distance between the tops of the horizontal members is less than 45 inches (1143 mm), the horizontal members shall be located on the swimming pool side of the fence. Spacing between vertical members shall not exceed $1\frac{3}{4}$ inches (44 mm) in width. Where there are decorative cutouts within vertical members, spacing within the cutouts shall not exceed $1\frac{3}{4}$ inches (44 mm) in width.

5. Where the barrier is composed of horizontal and vertical members and the distance between the tops of the horizontal members is 45 inches (1143 mm) or more, spacing between vertical members shall not exceed 4 inches (102 mm). Where there are decorative cutouts within vertical members, spacing within the cutouts shall not exceed $1\frac{3}{4}$ inches (44 mm) in width.

6. Maximum mesh size for chain link fences shall be a $2\frac{1}{4}$ -inch (57 mm) square unless the fence has slats fastened at the top or the bottom which reduce the openings to not more than $1\frac{3}{4}$ inches (44 mm).

7. Where the barrier is composed of diagonal members, such as a lattice fence, the maximum opening formed by the diagonal members shall not be more than $1\frac{3}{4}$ inches (44 mm).

8. Gates shall comply with the requirements of Section AG105.2, Items 1 through 7, and with the following requirements:

8.1. All gates shall be self-closing. In addition, if the gate is a pedestrian access gate, the gate shall open outward, away from the pool.

8.2. All gates shall be self-latching, with the latch handle located within the enclosure (i.e., on the pool side of the enclosure) and at least 40 inches (1016 mm) above grade. In addition, if the latch handle is located less than 54 inches (1372 mm) from the bottom of the gate, the latch handle shall be located at least 3 inches (76 mm) below the top of the gate, and neither the gate nor the barrier shall have any opening greater than 0.5 inch (12.7 mm) within 18 inches (457 mm) of the latch handle.

8.3. All gates shall be securely locked with a key, combination or other child proof lock sufficient to prevent access to the swimming pool through such gate when the swimming pool is not in use or supervised.

9. Where a wall of a dwelling serves as part of the barrier, one of the following conditions shall be met:

9.1. The pool shall be equipped with a powered safety cover in compliance with ASTM F 1346; or

9.2. Doors with direct access to the pool through that wall shall be equipped with an alarm which produces an audible warning when the door and/or its screen, if present, are opened. The alarm shall be listed in accordance with UL 2017. The audible alarm shall activate within 7 seconds and sound continuously for a minimum of 30 seconds after the door and/or its screen, if present, are opened and be capable of being heard throughout the house during normal household activities.

The alarm shall automatically reset under all conditions. The alarm system shall be equipped with a manual means, such as touch pad or switch, to temporarily deactivate the alarm for a single opening. Deactivation shall last for not more than 15 seconds. The deactivation switch(es) shall be located at least 54 inches (1372 mm) above the threshold of the door; or

9.3. Other means of protection, such as self-closing doors with self-latching devices, shall be acceptable so long as the degree of protection afforded is not less than the protection afforded by Item 9.1 or 9.2 described above.

10. Where an above-ground pool structure is used as a barrier or where the barrier is mounted on top of the pool structure, and the means of access is a ladder or steps:

10.1. The ladder or steps shall be capable of being secured, locked or removed to prevent access; or

10.2. The ladder or steps shall be surrounded by a barrier which meets the requirements of Section AG105.2, Items 1 through 9. When the ladder or steps are secured, locked or removed, any opening created shall not allow the passage of a 4-inch-diameter (102 mm) sphere.

G105.4 Indoor swimming pool. Walls surrounding an indoor swimming pool shall comply with Section AG105.2, Item 9.

G105.5 Prohibited locations. Barriers shall be located to prohibit permanent structures, equipment or similar objects from being used to climb them.

G105.6 Barrier exceptions. Spas or hot tubs with a safety cover which complies with ASTM F 1346, as listed in Section AG107, shall be exempt from the provisions of this appendix.

SECTION G106 ENTRAPMENT PROTECTION FOR SWIMMING POOL AND SPA SUCTION OUTLETS

G106.1 General. Suction outlets shall be designed to produce circulation throughout the pool or spa. Single-outlet systems, such as automatic vacuum cleaner systems, or multiple suction outlets, whether isolated by valves or otherwise, shall be protected against user entrapment.

G106.1.1 Compliance alternative. Suction outlets may be designed and installed in accordance with ANSI/APSP-7.

G106.2 Suction fittings. Pool and spa suction outlets shall have a cover that conforms to ANSI/ASME A112.19.8, or an 18 inch × 23 inch (457mm by 584 mm) drain grate or larger, or an approved channel drain system.

Exception: Surface skimmers

G106.3 Atmospheric vacuum relief system required. Pool and spa single- or multiple-outlet circulation systems shall be equipped with atmospheric vacuum relief should grate covers located therein become missing or broken. This vacuum relief system shall include at least one approved or engineered method of the type specified herein, as follows:

1. Safety vacuum release system conforming to ASME A112.19.17; or
2. An approved gravity drainage system.

G106.4 Dual drain separation. Single or multiple pump circulation systems have a minimum of two suction outlets of the approved type. A minimum horizontal or vertical distance of 3 feet (914 mm) shall separate the outlets. These suction outlets shall be piped so that water is drawn through them simultaneously through a vacuum-relief-protected line to the pump or pumps.

G106.5 Pool cleaner fittings. Where provided, vacuum or pressure cleaner fitting(s) shall be located in an accessible position(s) at least 6 inches (152 mm) and not more than 12 inches (305 mm) below the minimum operational water level or as an attachment to the skimmer(s).

SECTION G107 SWIMMING POOL AND SPA ALARMS

G107.1 Applicability. A swimming pool or spa installed, constructed or substantially modified after December 14, 2006, shall be equipped with an approved pool alarm.

Exceptions:

1. A hot tub or spa equipped with a safety cover which complies with ASTM F1346, as listed in Section AG109.
2. A swimming pool (other than a hot tub or spa) equipped with an automatic power safety cover which complies with ASTM F1346, as listed in Section AG109.

Pool alarms shall comply with ASTM F2208, as listed in Section AG109, and shall be installed, used and maintained in accordance with the manufacturer's instructions and this section.

G107.2 Multiple alarms. A pool alarm must be capable of detecting entry into the water at any point on the surface of the swimming pool. If necessary to provide detection capability at every point on the surface of the swimming pool, more than one pool alarm shall be provided.

G107.3 Alarm activation. Pool alarms shall activate upon detecting entry into the water and shall sound poolside and inside the dwelling.

G107.4 Prohibited alarms. The use of personal immersion alarms shall not be construed as compliance with this section.

SECTION G108 ABBREVIATIONS

G108.1 General.

ANSI—American National Standards Institute
11 West 42nd Street, New York, NY 10036

APSP—Association of Pool and Spa Professionals
2111 Eisenhower Avenue, Suite 500
Alexandria, VA 22314-4695

ASME—American Society of Mechanical Engineers
Three Park Avenue, New York, NY 10016-5990

ASTM—ASTM International
100 Barr Harbor Drive, West Conshohocken, PA 19428

NSPI—National Spa and Pool Institute
2111 Eisenhower Avenue, Alexandria, VA 22314

UL—Underwriters Laboratories, Inc.
333 Pfingsten Road
Northbrook, Illinois 60062-2096

SECTION G109 STANDARDS

G109.1 General.

ANSI/APSP

ANSI/P 7—06 American National
Standard for Suction Entrapment Avoidance
in Swimming Pools, Wading Pools, Spas,
Hot Tubs, and Catch Basins AG106.1.1

ANSI/NSPI

ANSI/NSPI-3—99 Standard for Permanently
Installed Residential Spas G104.1
ANSI/NSPI-4—99 Standard for
Above-ground/On-ground Residential AG103.2

Swimming Pools

ANSI/NSPI-5—03 Standard for Residential
In-ground Swimming Pools AG103.1

ANSI/NSPI-6—99 Standard for Residential
Portable Spas AG104.2

ANSI/ASME A112.19.8—07 Suction Fittings
for Use in Swimming Pools, Wading Pools,
Spas, Hot Tubs and Whirlpool Bathing
Appliances AG106.2

ASTM

ASTM F 1346—91 (1996) Performance
Specification for Safety Covers and
Labeling Requirements for All Covers
for Swimming Pools, Spas and
Hot Tubs AG105.2,
AG105.3,
AG105.6,
AG107.1

ASTM F2208—2008 Standard Specification
for Pool Alarms AG107.1

ASME

ANSI/E A112.19.8—07 Suction Fittings
for Use in Swimming Pools, Wading Pools,
Spas, Hot Tubs and Whirlpool
Bathing Appliances AG106.2

ASME A112.19.17—02 Manufacturers
Safety Vacuum Release Systems (SVRS)
for Residential and Commercial Swimming
Pool, Spa, Hot Tub and
Wading Pool AG106.3

UL

UL2017—2000 Standard for General-
purposebr> Signaling Devices and Systems—
with Revisions
through June 2004 AG105.3